

## TEST REPORT

*Results of Tests on brick Conducted in accordance with ASTM C67/C67M-18 Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile*  
01/28/2022

Name:	Glen-Gery Technical Services 433 South Pottsville Pike Shoemakersville, PA, 19555-0340	Plant:	Pittsburgh Plant			
Phone:	(p) (610) 562-3076	Sampled Date:	01/12/2022			
Report Number:	GGHRP645	Fired Date:	01/03/2022			
Description:	<b>Clay w/Additive Extruded Cored</b>					
<b>Absorption</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>Average</b>
24 Hour Cold Water (%)	1.4	1.5	1.4	1.3	1.4	1.4
5 Hour Boiling Water (%)	1.6	1.7	1.5	1.5	1.6	1.6
Saturation Coefficient	0.86	0.88	0.88	0.9	0.88	0.88
<b>Compressive Strength</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>Average</b>
<i>psi</i>	19,017	18,125	18,598	18,146	18,411	18,459
<i>MPa</i>	131	125	128	125	127	127
<b>IRA (Oven Dried Method)</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>Average</b>
<i>g/min/30 in.<sup>2</sup></i>	1.3	1.9	1.5	1.5	1.6	1.6
<b>Efflorescence</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	
<i>Efflorescence Detection</i>	Not Effloresced	Not Effloresced	Not Effloresced	Not Effloresced	Not Effloresced	

**The brick represented by the test results shown here comply with the physical property requirements of the standards listed below:**

- ASTM 32 - 13 Standard Specification for Sewer and Manhole Brick (Made from Clay or Shale)  
Grades: SM - SS / MM - MS
- ASTM 62 - 17 Standard Specification for Building Brick (Solid Masonry Units Made From Clay or Shale)  
Class: SW - MW - NW
- ASTM 216 - 19 Standard Specification for Facing Brick (Solid Masonry Units Made From Clay or Shale)  
Grades: SW - MW
- CSA - A82-14 Fired Masonry brick made from clay or shale  
Class: EG - IG



Mike Krzyzanowski  
Technical Services Manager